

Water Operations Supervisor  
Michael Kamler  
City of Kearney  
1220 East 26<sup>th</sup> Street  
Kearney, NE 68847



TELEPHONE · (308) 233-3242  
E-MAIL · [MKamler@kearneygov.org](mailto:MKamler@kearneygov.org)  
WEBSITE · [www.cityofkearney.org](http://www.cityofkearney.org)

January 6, 2025

***RE: Approved water infrastructure materials***

To whom it may concern:

Effective immediately, The City of Kearney Water Division will allow the following fittings to be used in the City of Kearney water system.

Fire Hydrant – meeting the AWWA Standard Specification C502

- Clow Medallion
  - Oil filled bonnet and stainless-steel shaft
  - iHydrant technology optional

Water Gate Valve – with brass or stainless-steel recessed operating nuts

- Clow
  - 2” brass or stainless-steel recessed operating nut

Tapping Sleeve – 4” to 16” taps

- Ford FTSS with stainless steel MJ outlet

Water Service – size 1” to 2”

- Copper tubing type K, see the existing standard specifications.
- CenCore HDPE – SDR 9 CTS, 250 psi
  - Ford CTS quick nut with tracer wire terminal
  - 12-gauge tracer wire

Please submit any alternative materials for consideration to Sarah Sawin at [ssawin@kearneygov.org](mailto:ssawin@kearneygov.org). Please contact myself at (308)233-3242 with any questions.

Sincerely yours,

**CITY OF KEARNEY**

A handwritten signature in black ink, appearing to be "Michael Kamler", written over a horizontal line.

Michael Kamler  
Water Operations Supervisor